

## REPORT MISURAZIONI


ID Campo Fac-Simile Data: gg/mm/aa Ora Inizio: hh:mm  
 ID Stringa  
 Marca Pannelli ADV Solar Power Pannelli in serie 1, in parallelo 1  
 Modello Pannelli ADV5M-36-18  
 Tolleranza: -5.00 .. 5.00%

Irraggiamento 841.00 [W/mq]  
 Temperatura Pannello 37.70 [°C]


Parametro	U.M.	Targa	Targa	Misurati	Riportati SCT
		Pannello	Stringa	Pann/Str	Pann/Str
Voc	[V]	21.00	21.00	40.28	39.00
Isc	[A]	1.21	1.21	1.40	1.40
Vmp	[V]	16.80	16.80	18.40	31.13
Imp	[A]	1.07	1.07	1.18	1.40
Pmax	[W]	17.83	17.98	33.47	43.45
Factor	[%]	70.74	70.74	57.57	65.00
Perdienza	[%]	8.97	8.97	21.68	21.68

Fac-Simile

**Curva caratteristica in corrente**



**Curva caratteristica in potenza**



Il tecnico

27/05/13

report\_Fac-Simile\_123456  
 Identificativo Strumento: TEST  
 FW version: 1.07b (15/10/2012)

, mod. TT Q7.5/5.2.1. R00